



SafemaxTM Fire Services

AN ISO 9001 : 2015 CERTIFIED COMPANY

Fire Protection & Safety Engineers

Maharashtra Fire Services License Holder

FORM B

[Section 3 (3) and Rule 4 (2)]

Six Monthly Certificate for Compliance of the Fire Prevention & Life Safety Measures

CERTIFICATE

Certified that we have carried out inspection of the Fire Fighting Systems installed in the following Building or Premises, Namely:

HERITAGE INTERNATIONAL SCHOOL

KASAR AMBOLI

TAL. MULSI, DIST. PUNE

We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period **JUL - 2023 TO DEC - 2023** as required under the provisions of the **MAHARASTHRA FIRE PREVENTION AND LIFE SAFETY MEASURES ACT, 2006 (Mah.III 2007)**. The details of the inspection & maintenance of Installations carried out by we mentioned in the report appended under herewith.

Place: Pune

WET TRIALS TAKEN AND WORKING OF THE SYSTEM FOUND IN GOOD CONDITION AS ON

DATE :- 12/06/2023

For SAFEMAX FIRE SERVICES

Authorized Signatory



H. O. : Shop No. 5 & 7, Shree Ganesh Appt.,
Sr. No. 79/1, Makate Nagar, Kothrud, Pune - 38
Ph: (020) : 25283925. Cell: +91 9923276723,
+91 7276067101 E-mail: info@safemaxfire.com

HYD : Shop No.2, # 8-45/4, Canara Nagar, Plot No. 41,
Annapurna Colony, Peerzadguda, Uppal, Hyderabad,
Telangana - 500039. Cell: +91 8008755101, 9618049003.
E-mail: safemaxfirehyd@gmail.com

Mumbai : D/2, Flat No. 2/10, C Wing, Opp. Apna Bazar,
Sector-1, Vashi, Navi-Mumbai - 400703.
Cell : +91 7276078101, 7276066101.
E-mail: safemaxfire.bom@gmail.com

Vadodara : 303, Gangotri Appt., Bhadran Nagar,
New Abhilasha Char Rasta, New Sama Road,
Vadodara, Gujarat. Cell: +91 +91 7276077101
E-mail: safemaxfirebrd@gmail.com



Website // : www.safemaxfire.com



Customer Care No. : +91 7276066101





पुणे महानगर प्रदेश विकास प्राधिकरण, पुणे
Pune metropolitan Region Development Authority, Pune

स.नं. १५२ - १५३, महाराजा सयाजीराव गायकवाड उद्योग भवन, अंध, पुणे - ४११००७,
S.No. 152 - 153, Maharaja Sayajirao Gaikwad Udyog Bhawan, Aundh, Pune - 411007
Ph. No: 020 - 259 33 344 / 356 / 333 फोन नं. ०२० - २५९ ३३ ३४४ ३५६ ३३३ Email :hqpmrda@gmail.com

FIRE/PMRDA/04-17/2017/10

Date:- 19- Apr-2017

To,
Heritage International School,
Village:- Kasar Amboli,
Tal:- Mulashi,
Pune.

Sub:- Fire Safety Compliance for your school Building
Ref:- (i) Your Letter No. 29 Dt.17/04/2017.

Dear sir,

With reference to your letter under reference (i) above this is to inform you that, the school Building at Gat No. 22 & 23, Mauje:- Kasar Amboli Tal:- Mulashi, Pune have complied with the fire prevention & fire safety requirement in accordance with NBC-2005.

Please ensure that the system provided for the protection of the school building should be maintained properly & regularly and certificate issued from the licensed agency should be submitted in the letter to this office on January & June every year.

1. The scope of this letter is restricted to fire protection arrangements only. This letter should not be treated/ presumed as an approval for civil / architectural drawings.
2. The area calculation statements TDR/FSI/FAR etc shall be subject to verification and letter of PMRDA's competent Authority.
3. The required Marginal Open spaces as per DCPR requirements mentioned in Regulation 15.1 kept open and obstruction free at all time.

This letter is issued considering the request of M/s Heritage International School, for submission to the CBSC Board Authorities. *Only*.

Thanking you



KK Bi

Director

Heritage International School
Kasar Amboli, Mulshi, Pune.

Yours faithfully,

Devendra Potphode
18/4/2017
(Devendra Potphode)
Chief Fire Officer,
PMRDA, PUNE

HERITAGE INTERNATIONAL SCHOOL



SHIVAM FIRE
ENTERPRISES

SHIVAM FIRE ENTERPRISES

Cert No. 30/21-22

FORM B

[Section 3 (3) and rule 4 (2)]

Six Monthly Certificate for JUNE 2021 for compliance
of the Fire Prevention and Life Safety Measures

CERTIFICATE

Certified that we have carried out inspection of the **Fire Hydrant System** installed in the following Building or Premises, namely :-

Heritage International School

Kasar Amboli
Tal. Mulshi, Dist. Pune

We further certify that these installation in the above mentioned buildings are maintained in good repair and efficient conditions during the Period JAN 2021 to JUNE 2021 as required under the provisions of the - **Maharashtra Fire Prevention and Life Safety Measures Act, 2006** (Mah. III of 2007) . The details fo the Inspection & Maintenance of installations carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 20.09.2021



For Shivam Fire Enterprises

Authorized Signatory
SHIVAM FIRE ENTERPRISES

License No. : MFS-LA/2021/RF-44
MFS-LA/2021/RD-35

Encl.: Annexure



SHIVAM FIRE
ENTERPRISES

Annexure to Form B
Ref. Cert no 30/21-22

Servicing of fire fighting system details

Heritage International School

Kasar Amboli

Tal. Mulshi, Dist. Pune

S.No.	DESCRIPTION	QTY	UNIT
1	Servicing of Booster Pump	1	Nos
2	Servicing of Booster Pump Starter	1	Nos
3	Servicing of Hydrant Valve	1	Nos
4	Servicing of Hose Box with Hose pipe & Branch Pipe	1	Nos
5	Servicing of Hose Reel	1	Nos

Place : Pune

Date : 20.09.2021

For SHIVAM FIRE ENTERPRISES



Office No. B - 101, Sujit Complex, Nr. Wadgaon Bridge, Sinhagad Road, Pune - 411041.
Tel. : 020-24395400 / E-mail: shivamfire101@gmail.com / Website : www.shivamfire.in